

ADDENDUM NO. 5
CITY OF HIALEAH
FIRE STATION NO.7-ROOFING & LWIC
HIALEAH, FLORIDA

MARCH 4, 2013

TO ALL CONCERNED

The original Contract Documents, for the Project entitled **CITY OF HIALEAH – FIRE STATION NO. 7-ROOFING AND LWIC BID NO. 2012/13-2000-00-027** is hereby amended as noted in this **Addendum No. 5**.

This **Addendum No. 5** consists of 1 Typed Pages, 0 Sketches, 0 Attachments and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: March 4, 2013
Carlos Lopez-Acting Purchasing Director

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 5** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents faxed immediately to City of Hialeah @ (305) 883-5871, and submitted with sealed bids.

IN THE CONTRACT DOCUMENTS:

Response to RFI from Unlimited Roofing Services, Inc dated 2/28/13:

1. The verbiage on the roof plan (page AA-1.1) calls for a 3 ply roof system, however, note 2.02B on the same page states "Roofing Membranes (4 ply)". Which is it, 3 or 4 ply?

3 ply

2. Note 2.02-A1 states:"At concrete decks with a mopped down system...etc. however, if you follow the NOA listed on the roof plan (09-0517.05) it is for a self adhered base sheet and a torch applied cap sheet? Here again which is it, hot mopped or self adhered?

Please install base and cap sheets as per NOA.

ROOFING AND LIGHTWEIGHT INSULATING CONCRETE - 2012/13-2000-00-027

ADDENDUM RECEIPT FORM

CITY OF HIALEAH

**FIRE STATION NO. 7
ROOFING AND LWIC**

ADDENDUM NO. 3

CONTRACTOR'S NAME _____

ADDRESS _____

PHONE NO. _____ **FAX NO.** _____

CONTACT NAME _____ **SIGNATURE** _____

THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY of HIALEAH @ (305) 883-5871.

<u>ADDENDUM</u>	<u>SIGNATURE</u>	<u>DATE</u>
5	_____	_____
_____	_____	_____
_____	_____	_____

ROOFING AND LIGHTWEIGHT INSULATING CONCRETE - 2012/13-2000-00-027

ARF